

Addendum # 1

DATE: June 7, 2019

Richards Consulting & Associates Limited
27317 Twp Rd 372
Red Deer County, Alberta T4E 1N9
Phone: 403-886-2919 Fax: 403-886-2733

PROJECT: Lac La Biche County, Craigend Grader Building, TR-32-2018-08

THIS ADDENDUM FORMS PART OF, AND WILL BE ADDED TO, THE FINAL SET OF DRAWINGS FOR THIS PROJECT. THE PROJECT WILL NOT BE CONSIDERED COMPLETED, AND THE ENGINEER SHALL NOT SUPPLY A CERTIFICATE OF COMPLETION FOR AN OCCUPANCY PERMIT, UNTIL THE FOLLOWING REQUIREMENTS HAVE BEEN MET. ACKNOWLEDGMENT OF THE RECEIPT OF THIS ADDENDUM SHALL BE SENT TO RICHARDS CONSULTING & ASSOCIATES LIMITED.

1. Telephone – Phone cable is trenched to SE corner of property near power pole location. Contractor will be responsible to bring both telephone and secondary power from this location to same location on drawings. Drawing changes are noted below.
2. DWG Page A1.0 – Notes changed to read:
 - *Underground Conduit & Power Poles by Utility Contractor.*
 - *Buried Secondary power by contractor.*
 - *Buried TELUS cable to building by contractor.*
3. DWG page E-1 – Another cable added for Telus just NORTH or to the right of the electrical meter and service.
4. Refer to the Question and Answer sheet dated June 7, 2019.

End of Addendum