



Lac La Biche County
welcoming by nature.

August 26, 2019

To the Contractor

RE: ADDENDUM NO. 1
Contract No. TR-32-2019-18
WSP File: 161-12797-00
Bridge File 9799, Beaver River, Township Road 653
Concrete Girder Bridge Construction and Other Work

Please find attached an addendum to the above noted contract.

Please initial and include this Addendum when submitting your completed tender to the McArthur Place County office in Lac La Biche, AB.

Sincerely,

Ali Memon, P.Eng.
Manager, Engineering Services

Attachment

cc: Brian Shapka, Senior Manager, Public Works
Brad Grant, WSP, Athabasca
Darren Passmore, WSP, Edmonton
Greg Adamson, WSP, Edmonton
Dave Armstrong, WSP, Red Deer

**Bridge File 9799
Beaver River – Township Road 653**

**Contract No. TR-32-2019-18
WSP File: 161-12797-00**

**Lac La Biche County
August 26, 2019**

RE: ADDENDUM NO. 1

1. Note to Bidders & Section 1.1 – Conditions for Tender Submissions:

The Contractor is advised the tender close/open dates have been revised to the following:

Tenders must be received no later than **2:00 p.m.** local time on **September 10, 2019** at the Tender Deposit (reception) Counter of the 2nd Floor, McArthur Place, 10307 100 Street in Lac La Biche, Alberta.

Tenders which have already been received may be re-submitted up until the revised tender close.

Tenders will be opened shortly after **2:00 p.m.** local time on **September 10, 2019** at the Tea Room, McArthur Place, 10307 100 Street in Lac La Biche, Alberta. Public may be present.

2. Section 2.3 – Unit Price Schedule:

The number of piles listed for Bid Item 8, Pile Set-up – H-Pile is revised from **32 piles** to **28 piles**. Please strike out and replace the number in the “Estimated Quantities” column.

This should also be updated in the Estimated Quantity Table on Drawing 49551-P.

3. Section 8.1 – Separate Drawings:

The following note from Drawing 49551-P:

“GIRDERS SHALL BE ERECTED AT AMBIENT TEMPERATURES COLDER THAN -15°C”

is revised to:

“GIRDERS SHALL **NOT** BE ERECTED AT AMBIENT TEMPERATURES COLDER THAN -15°C”

Please note the Drawing 49551-P has not been adjusted to reflect these changes and will be updated on Issued for Construction Drawings.

End of Addendum
Attachments: N/A